

1/2" to 1-1/4" Union End NPT Stem Up Open, Two-Way Valves General Instructions

Application

VB-7211 series stem up open, two-way valves control water from 20 to 281°F (-7 to 138°C) or steam to 281°F (138°C) maximum in heating or air conditioning systems. They are used for two-position or proportional control applications. Valve assemblies require an actuator and a valve linkage that must be purchased separately.




Danger: Do not use for combustible gas applications. The VB-7211 series valve packings are not rated for combustible gas applications, and if used in these applications, gas leaks and explosions could result.

Features


- Valve sizes 1/2" to 1-1/4"
- Equal percentage flow characteristics for two-position or proportional control of water or steam
- 250 psig pressure rating per ANSI Standards (B16.15-1985) for cast bronze bodies
- Spring-loaded TFE packing
- Union end American Standard Taper Pipe Thread (NPT) connections
- Straightway or angle body pattern

Applicable Literature

- TAC Valve Products Catalog, F-27384
- TAC Cross-Reference Guide, F-23638
- TAC Reference Manual, F-21683
- TAC Application Manual, F-21335
- Control Valve Sizing, F-13755
- Valve Selection Chart for Steam, F-11366
- Valve Selection Chart for Water, F-11080
- EN-205 Water System Guidelines, F-26080



VB-7211-0-3-P



VB-7211-0-4-P

SPECIFICATIONS

Table-1 Specifications/Models.

| Specifications | | | Valve Body Series VB-7211-0-3-P | Valve Body Series VB-7211-0-4-P |
|--|-----------------------|-------------------------------------|---|------------------------------------|
| Service | | | Chilled or Hot Water and Steam | |
| Flow Characteristics (Figure-1) | | | Equal Percentage | |
| Action | | | Stem Up Open | |
| Sizes | | | 1/2" to 1-1/4" | |
| Body Pattern | | | Angle | Straightway |
| Type of End Fitting | | | Union NPT | |
| Valve Materials | Body | | Bronze | |
| | Seat | | Bronze | |
| | Stem | | Stainless Steel | |
| | Plug | | Brass | |
| | Packing | | Spring-loaded TFE | |
| | Disc | | EPDM | |
| ANSI Pressure Class (Figure-2) | | | 250 (up to 400 psig below 150°F) ^a | |
| Maximum Inlet Pressure, Steam | | | 35 psig (241 kPa) | |
| Allowable Control Media Temperature | | | 20 to 281°F (-7 to 138°C) | |
| Allowable Differential Pressure for Water ^b | | | 35 psi (241 kPa) Max. for Normal Life (refer to "Cavitation Limitations on Valve Pressure Drop" on page 7) | |
| Allowable Differential Pressure for Steam ^b | | | 20 psi (138 kPa) | |
| Valve Size | C _v Rating | k _{vs} Rating ^c | Complete Valve Body Part Number | |
| 1/2" | 0.4 | 0.3 | VB-7211-0-3-1 | VB-7211-0-4-1 |
| | 1.3 | 1.1 | VB-7211-0-3-2 | VB-7211-0-4-2 |
| | 2.2 | 1.9 | VB-7211-0-3-3 | VB-7211-0-4-3 |
| | 4.4 | 3.8 | — | VB-7211-0-4-4 |
| | 5.0 | 4.3 | VB-7211-0-3-4 | — |
| 3/4" | 5.5 | 4.7 | VB-7211-0-3-5 | VB-7211-0-4-5 |
| | 7.5 | 6.5 | — | VB-7211-0-4-6 |
| | 8.5 | 7.4 | VB-7211-0-3-6 | — |
| 1" | 10 | 8.6 | — | VB-7211-0-4-7 |
| | 14 | 12 | VB-7211-0-3-7 | VB-7211-0-4-8 |
| | 16 | 14 | VB-7211-0-3-8 | — |
| 1-1/4" | 20 | 17 | — | VB-7211-0-4-9 |
| | 22 | 19 | VB-7211-0-3-9 | — |

^a Do not apply above pressure rating to piping system.

^b Maximum recommended differential pressure in open position. Do not exceed recommended differential pressure (pressure drop) or integrity of parts may be affected. Exceeding maximum recommended differential pressure voids product warranty.

^c $k_{vs} = m^3/h$ ($\Delta P = 100$ kPa) $C_v = k_{vs} \times 1.156$

Close-off Pressure Rating

The close-off pressure rating is dependent on the size of the valve, valve linkage, and the actuator. Consult the **TAC Valve Products Catalog, F-27384**, for close-off ratings.

Spring Return Position of Valve Assembly

For a valve assembly (valve, linkage, and actuator) to have a normal (spring return) position, the actuator must be of the spring return type. See Table-2 for spring return position of valve assemblies.

EPRI Edgemont Precision Rebuilders, Inc
 Matlack Industrial Center
 207 Carter Dr Unit C
 West Chester, PA 19382
 800-356-3774

Table-2 Required Compatible Actuators/Linkages

| Actuator Series | Required Valve Linkage | Spring Return Position |
|------------------------------|------------------------|-----------------------------|
| MA-5210, MA-5211, MA-5213 | AV-7600 ^a | Stem Up Normally Open |
| MF-5413, MF-5513 | AV-7600 & AV-601 | |
| MF-22203, MF-22303, MF-22323 | Included w/Actuator | None (Non-Spring Return) |
| MF-63103, MF-63123 | | |
| MK-2690 | AV-7400 | Stem Up Normally Open |
| MK-4601, MK-4611, MK-4621 | AV-401 | |
| MP-5210, MP-5211, MP-5213 | AV-7600 ^a | |
| MP-5410, MP-5411, MP-5413 | AV-7600 & AV-601 | |
| MP-5511, MP-5513 | | |
| MPR-5610, MPR-5611, MPR-5613 | | |
| MPR-5713 | | |
| MS-22353 | Included w/Actuator | None |

^a High ambient temperatures with high media temperatures in the valve may require the use of AV-601 in addition to AV-7600. See General Instructions for AV-7600 (F-26235) and AV-601 (F-19069) for details.

Flow Characteristics

All valves have modified equal percentage flow characteristics. That is, for equal increments of valve stem stroke, the change in flow rate with respect to valve stroke may be expressed as a constant percent of the flow rate at the time of the change. The change of flow rate with respect to valve stroke is relatively small when the valve plug is near the valve seat and relatively high when the valve plug is nearly wide open. See Figure-1 for typical modified equal percentage flow characteristics of VB-7211 series valve bodies.




Figure-1 Typical Modified Equal Percentage Flow Characteristics.

EPRI Edgemont Precision Rebuilders, Inc
 Matlack Industrial Center
 207 Carter Dr Unit C
 West Chester, PA 19382
 800-356-3774

Rangeability

Rangeability is the ratio of rated flow to the minimum controllable flow through a valve. Table-3 lists the rangeability for VB-7211 series of valves.

Table-3 Rangeability

| Valve Body Part Number | Nominal Rangeability | Valve Body Part Number | Nominal Rangeability | Valve Body Part Number | Nominal Rangeability |
|------------------------|----------------------|------------------------|----------------------|------------------------|----------------------|
| VB-7211-0-X-1 | 5:1 | VB-7211-0-X-4 | 40:1 | VB-7211-0-X-7 | 60:1 |
| VB-7211-0-X-2 | 15:1 | VB-7211-0-X-5 | 50:1 | VB-7211-0-X-8 | 75:1 |
| VB-7211-0-X-3 | 25:1 | VB-7211-0-X-6 | 60:1 | VB-7211-0-X-9 | 75:1 |

Temperature/Pressure Ratings

See Figure-2 for temperature and pressure ratings. Consult the appropriate valve linkage general instruction sheet for the effect of valve body ambient temperatures on specific actuators. Ratings conform with published values and disclaimer.

VB-7211-0-3-P, VB-7211-0-4-P (Union End Cast Bronze Body)

Standards: Pressure to ANSI B16.15 Class 250 with 400 psig up to 150°F decreasing to 321 psig at 281°F

Materials: ASTM B584




Figure-2 Temperature and Pressure Ratings for VB-7211 Series Valve Bodies.

EPRI Edgemont Precision Rebuilders, Inc
 Matlack Industrial Center
 207 Carter Dr Unit C
 West Chester, PA 19382
 800-356-3774

VALVE SIZING AND SELECTION

Water

Two-position

Two-position control valves are normally selected "line size" to keep pressure drop at a minimum. If it is desirable to reduce the valve below line size, then 10% of "available pressure" (that is, the pump pressure differential available between supply and return mains with design flow at the valve location) is normally used to select the valve.

Proportional

Proportional control valves are usually selected to take a pressure drop equal to at least 50% of the "available pressure." As "available pressure" is often difficult to calculate, the normal procedure is to select the valve using a pressure drop at least equal to the drop in the coil or other load being controlled (except where small booster pumps are used) with a minimum recommended pressure drop of 5 psi (34 kPa). When the design temperature drop is less than 60°F (33°C) for conventional heating systems, higher pressure drops across the valve are needed for good results (Table-4).

Table-4 Conventional Heating System.

| Design Temperature Load Drop °F (°C) | Recommended Pressure Drop ^a (% of Available Pressure) | Multiplier on Load Drop |
|--------------------------------------|--|-------------------------|
| 60 (33) or More | 50% | 1 x Load Drop |
| 40 (22) | 66% | 2 x Load Drop |
| 20 (11) | 75% | 3 x Load Drop |

^a Recommended minimum pressure drop = 5 psi (34 kPa).

Secondary Circuits with Small Booster Pumps: 50% of available pressure difference (equal to the drop through load, or 50% of booster pump head).

Water Capacity

See Table-5 for water capacity of VB-7211 series valves.

EPRI Edgemont Precision Rebuilders, Inc
Matlack Industrial Center
207 Carter Dr Unit C
West Chester, PA 19382
800-356-3774

Table-5 Water Capacity in Gallons Per Minute for VB-7211 Series.

| Valve Body Part Number | C _v Rating | Differential Pressure (ΔP in psi) | | | | | | | | | | | | |
|------------------------|-----------------------|-----------------------------------|------|------|------|------|------|------|------|------|------|------|------|------|
| | | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 15 | 20 | 35 |
| VB-7211-0-X-1 | 0.4 | 0.40 | 0.57 | 0.69 | 0.80 | 0.89 | 0.98 | 1.06 | 1.13 | 1.20 | 1.26 | 1.55 | 1.79 | 2.37 |
| VB-7211-0-X-2 | 1.3 | 1.30 | 1.84 | 2.3 | 2.6 | 2.9 | 3.2 | 3.4 | 3.7 | 3.9 | 4.1 | 5.0 | 5.8 | 7.7 |
| VB-7211-0-X-3 | 2.2 | 2.2 | 3.1 | 3.8 | 4.4 | 4.9 | 5.4 | 5.8 | 6.2 | 6.6 | 7.0 | 8.5 | 9.8 | 13 |
| VB-7211-0-4-4 | 4.4 | 4.4 | 6.2 | 7.6 | 8.8 | 9.8 | 11 | 12 | 12 | 13 | 14 | 17 | 20 | 26 |
| VB-7211-0-3-4 | 5.0 | 5.0 | 7.1 | 8.7 | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 19 | 22 | 30 |
| VB-7211-0-X-5 | 5.5 | 5.5 | 7.8 | 9.5 | 11 | 12 | 13 | 15 | 16 | 17 | 17 | 21 | 25 | 33 |
| VB-7211-0-4-6 | 7.5 | 7.5 | 11 | 13 | 15 | 17 | 18 | 20 | 21 | 23 | 24 | 29 | 34 | 44 |
| VB-7211-0-3-6 | 8.5 | 8.5 | 12 | 15 | 17 | 19 | 21 | 22 | 24 | 26 | 27 | 33 | 38 | 50 |
| VB-7211-0-4-7 | 10 | 10 | 14 | 17 | 20 | 22 | 24 | 26 | 28 | 30 | 32 | 39 | 45 | 59 |
| VB-7211-0-3-7 | 14 | 14 | 20 | 24 | 28 | 31 | 34 | 37 | 40 | 42 | 44 | 54 | 63 | 83 |
| VB-7211-0-4-8 | | 16 | 23 | 28 | 32 | 36 | 39 | 42 | 45 | 48 | 51 | 62 | 72 | 95 |
| VB-7211-0-3-8 | 16 | 16 | 23 | 28 | 32 | 36 | 39 | 42 | 45 | 48 | 51 | 62 | 72 | 95 |
| VB-7211-0-4-9 | 20 | 20 | 28 | 35 | 40 | 45 | 49 | 53 | 57 | 60 | 63 | 77 | 89 | 118 |
| VB-7211-0-3-9 | 22 | 22 | 31 | 38 | 44 | 49 | 54 | 58 | 62 | 66 | 70 | 85 | 98 | 130 |

C_v Equation

$$C_v = \frac{\text{GPM}}{\sqrt{\Delta P}} \quad \Delta P = \left(\frac{\text{GPM}}{C_v} \right)^2 \quad \text{GPM} = C_v \sqrt{\Delta P}$$

Where:

C_v = Coefficient of flow

GPM = U.S. gallons per minute (60°F, 15.6°C)

ΔP = Differential pressure in psi (pressure drop)

Steam

Two-position

Two-position zone valves and direct radiation valves are normally sized using a minimum of 10% of inlet pressure (psig).

Proportional

Proportional control valves are normally sized using:

- For low pressure (15 psig or less), use ΔP of 80% of gauge inlet pressure.
- For steam pressures greater than 15 psig, use ΔP of 42% of absolute (gauge plus 14.7 psig) inlet pressure.
- When the C_v required is between two valve sizes, select the larger size. Do not size steam valves using a pressure drop greater than 42% of the absolute inlet pressure.

Steam Capacity

See Table-6 for steam capacity of VB-7211 series valves.

Table-6 Steam Capacity in Pounds Per Hour for VB-7211 Series.

| Valve Body Part Number | Cv Rating | Differential Pressure (ΔP in psi) ^a | | | | | | | | | | | | | | | |
|------------------------|-----------|---|-----|--------------|-----|---------------|-----|---------------|-----|---------------|------|---------------|------|---------------|------|---------------|------|
| | | 2 psig Inlet | | 5 psig Inlet | | 10 psig Inlet | | 15 psig Inlet | | 20 psig Inlet | | 25 psig Inlet | | 30 psig Inlet | | 35 psig Inlet | |
| | | 0.2 | 1.6 | 0.5 | 4 | 1 | 8 | 1.5 | 12 | 2 | 14 | 2.5 | 16 | 3 | 18 | 3.5 | 20 |
| VB-7211-0-X-1 | 0.4 | 2.2 | 5.9 | 3.7 | 9.5 | 5.8 | 14 | 7.8 | 18 | 9.7 | 20 | 12 | 23 | 13 | 26 | 15 | 29 |
| VB-7211-0-X-2 | 1.3 | 7.1 | 19 | 12 | 31 | 19 | 45 | 25 | 57 | 32 | 66 | 38 | 76 | 44 | 86 | 50 | 95 |
| VB-7211-0-X-3 | 2.2 | 12 | 32 | 20 | 52 | 32 | 76 | 43 | 96 | 53 | 112 | 64 | 129 | 74 | 145 | 84 | 161 |
| VB-7211-0-4-4 | 4.4 | 24 | 65 | 41 | 105 | 64 | 153 | 86 | 192 | 107 | 225 | 127 | 257 | 148 | 289 | 168 | 322 |
| VB-7211-0-3-4 | 5.0 | 27 | 74 | 46 | 119 | 73 | 173 | 98 | 219 | 121 | 255 | 145 | 292 | 168 | 329 | 191 | 366 |
| VB-7211-0-X-5 | 5.5 | 30 | 81 | 51 | 131 | 80 | 191 | 107 | 240 | 133 | 281 | 159 | 321 | 185 | 362 | 210 | 402 |
| VB-7211-0-4-6 | 7.5 | 41 | 111 | 70 | 178 | 110 | 260 | 146 | 328 | 182 | 383 | 217 | 438 | 252 | 493 | 286 | 548 |
| VB-7211-0-3-6 | 8.5 | 46 | 125 | 79 | 202 | 124 | 295 | 166 | 372 | 206 | 434 | 246 | 497 | 285 | 559 | 324 | 621 |
| VB-7211-0-4-7 | 10 | 55 | 147 | 93 | 238 | 146 | 347 | 195 | 437 | 243 | 511 | 289 | 584 | 336 | 658 | 381 | 731 |
| VB-7211-0-3-7 | 14 | 76 | 206 | 130 | 333 | 204 | 485 | 273 | 612 | 340 | 715 | 405 | 818 | 470 | 921 | 534 | 1024 |
| VB-7211-0-4-8 | | | | | | | | | | | | | | | | | |
| VB-7211-0-3-8 | 16 | 87 | 236 | 149 | 380 | 234 | 555 | 312 | 699 | 388 | 817 | 463 | 935 | 537 | 1052 | 610 | 1170 |
| VB-7211-0-4-9 | 20 | 109 | 295 | 186 | 475 | 292 | 694 | 390 | 874 | 485 | 1021 | 579 | 1168 | 671 | 1315 | 763 | 1462 |
| VB-7211-0-3-9 | 22 | 120 | 324 | 204 | 523 | 321 | 763 | 429 | 962 | 534 | 1123 | 636 | 1285 | 738 | 1447 | 839 | 1608 |

^a Values are for saturated steam (K = 1). Left column under each inlet pressure is for two-position control, and right column is for proportional control

C_v Equation

$$C_v = \frac{QK}{3\sqrt{\Delta P \cdot P_2}} \quad Q = \frac{3C_v\sqrt{\Delta P \cdot P_2}}{K}$$

Where:

C_v = Coefficient of flow

Q = Lbs. per hour of steam

ΔP = Differential pressure in psi (pressure drop)

P₂ = Outlet pressure in psia (absolute) (P₂ = Inlet pressure + 14.7 - ΔP)

K = 1 + (0.0007 x °F superheat) (K = 1 for saturated steam)

EPRI Edgemont Precision Rebuilders, Inc
 Matlack Industrial Center
 207 Carter Dr Unit C
 West Chester, PA 19382
 800-356-3774

Cavitation Limitations on Valve Pressure Drop

A valve selected with too high a pressure drop can cause erosion of discs and/or wire drawing of the seat. In addition, cavitation can cause noise, damage to the valve trim (and possibly the body), and choke the flow through the valve.

Do not exceed the maximum differential pressure (pressure drop) for the valve selected.

The following formula can be used on higher temperature water systems, where cavitation could be a problem, to estimate the maximum allowable pressure drop across the valve:

$$P_m = 0.5 (P_1 - P_v)$$

Where:

P_m = Maximum allowable pressure drop (psi)

P_1 = Absolute inlet pressure (psia)

P_v = Absolute vapor pressure (psia) (refer to Table-6 or Table-7)

Note: Add 14.7 psi to gauge supply pressure to obtain absolute pressure value.

For example, if a valve is controlling 200°F water at an inlet pressure of 18 psig, the maximum pressure drop allowable would be:

$$P_m = 0.5 [(18 + 14.7) - 11.53] = 10.6 \text{ psi}$$

(Vapor pressure of 200°F water is 11.53 psia)

If the pressure drop for this valve is less than 10.6 psi, cavitation should not be a problem.

Systems where cavitation is shown to be a problem can sometimes be redesigned to provide lower inlet velocities. Valves having harder seat materials should be furnished if inlet velocities cannot be lowered.

Table-7 Vapor Pressure of Water Table.

| Water Temp. (°F) | Vapor Pressure (psia) | Water Temp. (°F) | Vapor Pressure (psia) | Water Temp. (°F) | Vapor Pressure (psia) | Water Temp. (°F) | Vapor Pressure (psia) |
|------------------|-----------------------|------------------|-----------------------|------------------|-----------------------|------------------|-----------------------|
| 40 | 0.12 | 90 | 0.70 | 140 | 2.89 | 190 | 9.34 |
| 50 | 0.18 | 100 | 0.95 | 150 | 3.72 | 200 | 11.53 |
| 60 | 0.26 | 110 | 1.28 | 160 | 4.74 | 210 | 14.12 |
| 70 | 0.36 | 120 | 1.69 | 170 | 5.99 | 220 | 17.19 |
| 80 | 0.51 | 130 | 2.22 | 180 | 7.51 | 230 | 20.78 |

Additional Valve Sizing Information

For additional valve sizing information, see:

- CA-28 Control Valve Sizing, F-13755
- Valve Selection Chart Water, F-11080
- Valve Selection Chart Steam, F-11366
- Valve Sizing Slide Rule, TOOL-150

EPRI Edgemont Precision Rebuilders, Inc
 Matlack Industrial Center
 207 Carter Dr Unit C
 West Chester, PA 19382
 800-356-3774

INSTALLATION

Inspection

Inspect the package for damage. If damaged, notify the appropriate carrier immediately. If undamaged, open the package and inspect the device for obvious damage. Return damaged products.

Requirements

- Tools (not provided): Pipe wrenches
- Training: Installer must be a qualified, experienced technician
- Appropriate accessories

Caution:

- Install the valve with the flow in the direction of the flow arrow ("A" port the inlet and "AB" port the outlet).
 - Do not exceed the ratings of the device.
 - Avoid locations where excessive moisture, corrosive fumes or vibration are present.
-

Mounting

1. The valve should be mounted in a weather protected area in a location that is within the ambient limits of the actuator. When selecting a location, allow sufficient room for valve linkage, actuator, and other accessories and for service of the product.
2. The preferred mounting position for the valve is with the valve stem vertical above the valve body. Avoid mounting the valve so that the valve stem is below horizontal.
3. For steam applications only, position the valve body so the valve stem and actuator are at least at 45° from vertical.
4. The valves must be piped with the "A" port as the inlet and the "AB" port as the outlet.

Union End NPT Valve Bodies


The VB-7211 series of union valve bodies conform to American Standard Taper Pipe Threads (NPT).

1. Apply pipe dope sparingly to all but the last two threads of a properly threaded, reamed, and cleaned pipe. Be sure that pipe chips, scale, etc. do not get into the pipe since this material may lodge in the valve seat and prevent proper closing and opening of the valve.
2. Start the joint by hand screwing the pipe into the valve. If the thread engagement feels "right," turn the pipe by hand as far as it will go.
3. Use a pipe wrench to fully tighten the valve to the pipe. Do not over tighten or strip threads. See Table-8 and Figure-3 for the normal engagement length of the threads. Figure-4 shows means of tightening the pipe so that valve is not twisted or crushed.

Table-8 Normal Thread Engagement Between Male Pipe Thread and Valve Body.

| Valve Size Inches (NPT) | Normal Engagement |
|-------------------------|-------------------|
| 1/2" | 1/2" |
| 3/4" | 9/16" |
| 1" | 11/16" |
| 1-1/4" | 11/16" |

EPRI Edgemont Precision Rebuilders, Inc
Matlack Industrial Center
207 Carter Dr Unit C
West Chester, PA 19382
800-356-3774



Pipe threads too long.
Pipe interferes with seat.

Figure-3 Normal Thread Engagement.




Figure-4 Installation of Union End Valves.

EPRI Edgemont Precision Rebuilders, Inc
 Matlack Industrial Center
 207 Carter Dr Unit C
 West Chester, PA 19382
 800-356-3774

CHECKOUT

1. Make sure the valve stem operates smoothly before installing the valve linkage and the actuator.
2. If the stem does not operate smoothly, it may indicate that valve was twisted or crushed during installation or that stem was bent by rough handling. These conditions may require that the valve be replaced.
3. After the piping is under pressure, check the valve body and the connections for leaks.
4. After the valve linkage and the actuator are installed, check their operation.
 - a. Power the actuator and run the valve to the stem down position. Make sure the linkage and valve stem move freely. At the stem down position, the valve should shut off tightly.
 - b. For spring return actuators, allow the actuator to spring return to the stem up position. Again, the valve stem and linkage should operate smoothly. At the stem up position, the valve should be in its full open position.

MAINTENANCE & FIELD REPAIR

Regular maintenance of the total system is recommended to assure sustained performance. See Table-9 for maintenance kit part numbers.

Table-9 Maintenance Kits for VB-7211 Valves.

| Valve Body Part Number | Replacement Packing Assembly | Packing Wrench | Valve Repair Kit ^a |
|------------------------|------------------------------|----------------|-------------------------------|
| VB-7211-0-X-1 | YBA-622-1 | TOOL-20-1 | RYB-721-1 |
| VB-7211-0-X-2 | | | RYB-721-2 |
| VB-7211-0-X-3 | | | RYB-721-3 |
| VB-7211-0-X-4 | | | RYB-721-4 |
| VB-7211-0-X-5 | | | RYB-721-5 |
| VB-7211-0-X-6 | | | RYB-721-6 |
| VB-7211-0-X-7 | | | RYB-721-7 |
| VB-7211-0-3-8 | | | RYB-721-A8 |
| VB-7211-0-4-8 | | | RYB-721-8 |
| VB-7211-0-X-9 | | | RYB-721-9 |

^a Kit includes replacement packing and stem & plug assembly.

Water System Maintenance

All heating and cooling systems are susceptible to valve and system problems caused by improper water treatment and system storage procedures. These guidelines are provided to help avoid valve and water system problems resulting from improperly treated water or storage procedures in cooling and hot water systems, and to obtain maximum life from TAC valves.

Durability of valve stems and packings is dependent on maintaining non-damaging water conditions. Inadequate water treatment or filtration, not in accordance with chemical supplier/ASHRAE handbook recommendations, can result in corrosion, scale, and abrasive particle formation. Scale and particulates can result in stem and packing scratches and can adversely affect packing life and other parts of the hydronic system.

To maintain non-damaging conditions, follow these guidelines:

- Clean the system prior to start up. Use a nitrite or molybdate-based treatment program.
- Use filtration equipment where needed.
- Properly store off-line systems and monitor water treatment results using corrosion test coupons.
- Follow the advice of a water treatment professional.
- Consult **EN-205, Water System Guidelines Engineering Information, F-26080**, for further details.

EPRI Edgemont Precision Rebuilders, Inc
 Matlack Industrial Center
 207 Carter Dr Unit C
 West Chester, PA 19382
 800-356-3774

F-24380-2

DIMENSIONAL DATA

Table-10 Dimensions for VB-7211-0-3-P Series Angle Valves (Figure-5).

| Valve Body Part Number | Valve Size | Dimensions in Inches (mm) | | | | |
|--|------------|---------------------------|--------------|-------------|---------------|-------------------------|
| | | A | B | C | D (Stem Down) | E ^a (Stroke) |
| VB-7211-0-3-1 VB-7211-0-3-2 VB-7211-0-3-3 VB-7211-0-3-4 | 1/2" | 3-1/8 (79) | 1-5/8 (41) | 1-5/16 (33) | 3/4 (19) | 7/16 (11) |
| VB-7211-0-3-5 VB-7211-0-3-6 | 3/4" | 3-5/8 (92) | 1-11/16 (43) | 1-1/2 (38) | | |
| VB-7211-0-3-7 VB-7211-0-3-8 | 1" | 4-1/16 (103) | 1-15/16 (49) | 2-1/8 (54) | | |
| VB-7211-0-3-9 | 1-1/4" | 4-5/16 (110) | 2-3/16 (56) | 2-1/4 (57) | | |

^a Stroke for rated flow. Add up to 1/16 in. (1.6 mm) for disc seating and compression.




Figure-5 Dimensions for VB-7211-0-3-P Series Angle Valve Bodies.

EPRI Edgemont Precision Rebuilders, Inc
 Matlack Industrial Center
 207 Carter Dr Unit C
 West Chester, PA 19382
 800-356-3774

Table-11 Dimensions for VB-7211-0-4-P Series Straightway Valves (Figure-6).

| Part Number | Valve Size | Dimensions in Inches (mm) | | | | |
|--|------------|---------------------------|-------------|--------------|---------------|------------|
| | | A | B | C | D (Stem Down) | E (Stroke) |
| VB-7211-0-4-1 VB-7211-0-4-2 VB-7211-0-4-3 VB-7211-0-4-4 | 1/2" | 4-3/16 (106) | 1-1/16 (27) | 1-11/16 (43) | 3/4 (19) | 7/16 (11) |
| VB-7211-0-4-5 VB-7211-0-4-6 | 3/4" | 4-15/16 (125) | | | | |
| VB-7211-0-4-7 VB-7211-0-4-8 | 1" | 6 (152) | 1-1/8 (29) | 2-3/8 (60) | | |
| VB-7211-0-4-9 | 1-1/4" | 6-1/4 (159) | 1-3/8 (35) | | | |




Figure-6 Dimensions for VB-7211-0-4-P Series Straightway Valve Bodies.

Copyright 2008, TAC
All brand names, trademarks and registered trademarks are the property of their respective owners. Information contained within this document is subject to change without notice.

F-24380-2

EPRI Edgemont Precision Rebuilders, Inc
Matlack Industrial Center
207 Carter Dr Unit C
West Chester, PA 19382
800-356-3774

t.a.c.[®]
by Schneider Electric